



A P P R O V A L S ®

Certificate of Suitability

* Addendum *

Certificate No.: SAA191845

Date of Issue: 15 July 2019

Class Description: Non-Declared

Product Description: Hybrid Inverter

General Modification:

Firmware version: 010109

Additional Models	Trade Name	Rating
GW3600-EH	GOODWE	PV Input: 580Vdc Max, MPPT voltage range 100-550Vdc 12.5/12.5A Isc PV 15.2/15.2A Grid input: 230V~ 50Hz 32A 7200VA Grid output: 230V~ 50Hz 16A 3600VA Backup: 230V~ 50Hz 15.7A 3600VA Battery: 85-450Vdc Charge/Discharge 25/25A
GW5000-EH	GOODWE	PV Input: 580Vdc Max, MPPT voltage range 100-550Vdc 12.5/12.5A Isc PV 15.2/15.2A Grid input: 230V~ 50Hz 43.4A 10000VA Grid output: 230V~ 50Hz 21.7A 5000VA Backup: 230V~ 50Hz 21.7A 5000VA Battery: 85-450Vdc Charge/Discharge 25/25A


For and on Behalf of
SAA Approvals Pty Ltd

SAA Approvals Pty Ltd as accredited by JAS-ANZ under ISO/IEC 17065 certifies in accordance with the SAA Approvals Electrical Product Safety Certification Scheme that the product nominated in this certificate complies with standard/s listed.

When using the RCM the requirements of all relevant parts of AS/NZS 4417 applicable to the article must be fulfilled.

For SAA Contact Details and to verify this Certificate go to:
www.saaapprovals.com.au

JAS-ANZ



www.jas-anz.org/register



Issued: 15-07-19 191845/2